



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA173168

Certificate Holder: Aryam Australia Pty Ltd T/as
Znergy Cable Australia
Level 26, 71 Eagle Street
Brisbane QLD 4000
Australia

Class Description: Non-Declared
Product Description: Nylon termite protected HV Electrical Cable
(All cable sizes up to 800mm²;
copper or aluminium conductors;
single-core, three-core and triplex)

Brand Name: 
Model No.: ZXL-V33
Markings: 19/33kV
Standard: AS/NZS 1429.1:2006
Conditions: Nil

Certification Mark: SAA173168 or RCM

Date First Registered: 1 March 2018
Date of Expiry: 1 March 2023




For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 05-03-18 173168/1a
Revised Prod Desc.