

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50435512

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
A.S.

Unser Zeichen *Our Reference*
01-WSW-50104079 002

Ausstellungsdatum *Date of Issue*
30.04.2019 (day/mo/yr)

Genehmigungsinhaber *License Holder*
ARYAM AUSTRALIA PTY LTD
71 EAGLE STREET,
BRISBANE QLD 4000
Australia

Fertigungsstätte *Manufacturing Plant*
030-0000472483

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance
www.tuv.com
ID 1419088702

Geprüft nach *Tested acc. to*
EN 50618:2014

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Cables (Electric Cables for Photovoltaic Systems)

Type Designation : H1Z2Z2-K 1X1,5...240mm² Znergy

19

Rated Voltage : DC 1,5kV
AC 1,0/1,0kV

Ambient Temperature : -40°C to +90°C

Max. Temperature
at Conductor : 120°C

19

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 <http://www.tuv.com/safety>



Jie Zhang